

Evidence of Performance

Resistance to wind load
Watertightness
Air permeability

Test Report 102 42739/1e



Client **Kompen PVC Yapi ve Insaat Malzemeleri Sanayi Ticaret A.S.**
Istanbul Yolu 45. km. Ladik Mevkii

42435 Sarayönü
Turkey

Basis

EN 14351-1 : 2006-03

Test standards:

EN 1026 : 2000-06

EN 1027 : 2000-06


EN 12211 : 2000-06

EN 12046-1 : 2003-11

EN 14609 : 2004-03

Corresponds to the national standard (DIN EN)

Representation



Product	Single leaf tilt and turn window
System	KOM 500
Overall dimensions (w x H)	700 mm x 1,300 mm
Frame material	PVC-U/white Bracings mitred and mounted without cutback. Locking points under maximum hold. Glazing rebate horizontal at bottom additional sealed with
Special features	pourable sealant.

Instruction for use

The present test report serves to demonstrate the above characteristics of windows according to EN 14351-1:2006-03. The results obtained can be used by the manufacturer as the basis for the manufacturer ITT test report summary. The conditions and requirements set out by EN 14351-1:2006-03 shall be observed.

Validity

The data and results refer solely to the tested and described specimen.

The test results can be extrapolated as per EN 14351-1, under observance of Annex E 1., under the manufacturer's own responsibility.

The test does not allow any statement to be made on further characteristics of the present structure and quality, in particular the effects of weathering and ageing.

Resistance to wind load – EN 12210



Class C4

Watertightness – EN 12208



Class 8A

Air permeability – EN 12207



Class 4

ift Rosenheim
30. July 2010


Jörg Peter Lass, Dipl.-Ing. (FH)
Head of Testing Department
ift Centre Windows & Facades


Robert Kolacny, Dipl.-Ing. (FH)
Test engineer
ift Centre Windows & Facades

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

The cover sheet can be used as an abstract.

Contents

The report contains a total of 9 pages



ift Rosenheim GmbH
Geschäftsführer:
Dipl.-Ing. (FH) Ulrich Sieberath
Dr. Jochen Peichl

Theodor-Gieter-Str. 7 - 9
D-83026 Rosenheim
Tel.: +49 (0)8031/261-0
Fax: +49 (0)8031/261-290
www.ift-rosenheim.de

Sitz: 83026 Rosenheim
AG Traunstein, HRB 14763
Sparkasse Rosenheim
Kto. 3822
BLZ 711 500 00

Notified Body Nr.: 0757
Anerkannte PUZ-Stelle: BAY 18
 DAP-PL-0908 99
DAP-ZE-2288 00
TGA-ZM-16-93-00
TGA-ZM-16-93-60